Texas Commission on Environmental Quality Public Notification Form for Wastewater Discharges

Information about the Discharge

An unauthorized discharge or spill of wastewater has occurred from: Our Wastewater Collection System

Facility Name: Montgomery County WCID#1 Wastewater Treatment Facility

Person to contact for information: Richard J Hughes at 2813670969

Location of spill(s):23802 Glen Loch Dr, Spring, Tx, 77380

Estimated date and time of spill(s): 07/09/24 @ 8:00am until 07/10/24 @ 1:45pm.

Estimated volume of spill(s)(number of gallons): 452,000 gallons.

Type of Spill: Domestic,

Description of the area potentially affected, including down gradient and lateral distance from spill(s) site: Within 1/2 mile from 23802 Glen Loch, Spring, Tx, 77380.

Suspected cause of spill(s): Intense, sustained rainfall from Hurricane Beryl resulted in the spill of domestic wastewater greater than 100,000 gallons.

List of actions taken including but, not limited to:

Notification of: TCEQ Regional Office: 12.

Customers of Montgomery County WCID# 1 thru Blackboard direct message ,The District web site, and Facebook.

Containment of spill: Contained within the Treatment Plant Site.

Increased monitoring of water supply systems: N/A Initiation or completion

of cleanup activities: Site was cleaned by Hydroclear vactor service.

If the Wastewater Spill meets the following conditions:

1. The spill is 50,000 gallons or more where one or more of the following conditions also exists: The spill is 100,000 gallons or more.

Precautionary Statement IF YOU RECIEVEYOUR DRINKING WATER FROM MONTGOMERY COUNTY WCID#1, YOUR WATER IS SAFEFROM THIS SPILL AND YOU DO NOT NEED TO BOILPYOUR WATER.

- Persons using private drinking water supply wells located within ½ mile of the spill site or within the potentially affected area should use only water that has been distilled or boiled at a rolling boil for at least one minute for all personal uses including drinking, cooking, bathing, and tooth brushing. Individuals with private water wells should have their well water tested and disinfected, if necessary, prior to discontinuing distillation or boiling.
- 2. Persons who purchase water from a public water supply may contact their water supply distributor to determine if the water is safe for personal use.
- 3. The public should avoid contact with waste material, soil, or water in the area potentially affected by the spill.
- 4. If the public comes into contact with waste material, soil, or water potentially affected by the spill, they should bathe and wash clothes thoroughly as soon as possible.